

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 1, Insert 1A, Page 1 of 1
Insert between pages XII and 1

SPS 365.0101 Administration. Except for IFGC section 102.8, the requirements in IFGC chapter 1 are not included as part of this chapter.

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 2, Insert 2A, Page 1 of 1
Insert between pages 10 and 11

SPS 365.0202 Definitions.

(1) ADDITIONS. This is a department definition for this chapter in addition to the definitions in IFGC section 202: “DHS” means the department of health services.

(2) SUBSTITUTIONS. This is a department substitution for the corresponding definition in IFGC section 202: “Approved” has the meaning given in s. SPS 362.0202 (2).

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 3 Insert 3A, Page 1 of 1
Insert between pages 20 and 21

SPS 365.0300 Statutory requirements. These are department informational notes to be used under IFGC chapter 3:

Note: Section 101.16 (4), Stats., requires “(a) The person actually performing the work of installing equipment utilizing liquefied petroleum gas for fuel purposes shall furnish the user of the equipment a statement, the form of which shall be prescribed by the department, showing that the design, construction, location, and installation of the equipment conforms with the rules promulgated by the department under this section.

(b) 1. A person who owns, leases, or uses a propane gas system and who is a customer of a retail supplier shall notify the retail supplier of propane gas for the propane gas system of any interruption in the operation of the propane gas system due to the replacement, modification, repair, or servicing of the propane gas system by any person other than the retail supplier. The customer shall provide the notice at least 7 days in advance of the interruption in the operation of the propane gas system, except as provided in subd. 2. The retail supplier, or the person replacing, modifying, repairing, or servicing the propane gas system, shall perform a check for leaks or other defects in the propane gas system before placing the propane gas system back into operation in the manner required by rule.

2. If the interruption of a propane gas system subject to subd. 1. is due to emergency repair or servicing, the customer shall provide the notice to the retail supplier as soon as possible and no later than 24 hours after the repair or servicing is completed.”

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 3, Insert 3B, Page 1 of 1
Insert between pages 20 and 21

SPS 365.0301 General regulations.

(1) SCOPE. Substitute the following wording for the requirements in IFGC section 301.1: This chapter shall govern the approval and installation of all equipment and appliances that comprise parts of the installations regulated by this code.

(2) LISTED AND LABELED. Substitute the following wording for the requirements in IFGC section 301.3: The requirements as specified in s. SPS 364.0301 (3) shall apply.

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 3, Insert 3C, Page 1 of 1
Insert between pages 22 and 23

SPS 365.0303 Appliance location.

(1) GENERAL. This is a department rule in addition to the requirements in IFGC section 303.1: If the air entering the heat exchanger of all gas-fired equipment is 30oF or lower, the heat exchanger and burners shall be constructed of corrosion-resistant materials.

(2) PROHIBITED LOCATIONS. The exceptions 3. and 4. in IFGC section 303.3 are not included as a part of this code.

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 3, Insert 3D, Page 1 of 1
Insert between pages 22 and 23

SPS 365.0304 Combustible air. Barometric dampers may not be used for combustion air.

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 4, Insert 4A, Page 1 of 1
Insert between pages 32 and 33

SPS 365.0400 Gas piping installations. Substitute the following wording for the requirements and exceptions in IFGC chapter 4: All gas piping and gas piping installations shall comply with NFPA 54, National Fuel Gas Code.

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 5, Insert 5A, Page 1 of 1
Insert between pages 86 and 87

SPS 365.0501 Chimneys and vents.

(1) This is a department informational note to be used under IFGC chapter 5: Note: For DHS licensed healthcare facilities as specified in chs. DHS 124, 132, and 134, also refer to NFPA 211 as adopted in these chapters.

(2) The requirements in section IFGC 501.8 item 8 are not included as a part of this chapter.

(3) Substitute the following wording for the requirements in section IFGC 501.8 item 10: Infrared radiant heaters listed for unvented use and not provided with flue collars.

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 5, Insert 5B, Page 1 of 1
Insert between pages 88 and 89

SPS 365.0502 Door swing. The requirements in IFGC section 502.7.1 are not included as part of chs. SPS 361 to 366.

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 6, Insert 6A, Page 1 of 1
Insert between pages 128 and 129

SPS 365.0621 Unvented heaters. Substitute the following wording for the requirements in IFGC section 621: Por- table or permanently installed, gas-fired, unvented heating appliances may not be installed, except during construction or demolition of a building if the appliances are provided in accordance with ch. SPS 314.

Note: See s. SPS 364.0801 (2) for use of portable unvented heating appliances that are fired with other fuels.

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 6, Insert 6B, Page 1 of 1
Insert between pages 132 and 133

SPS 365.0630 Infrared radiant heaters. This is a department rule in addition to the requirements in IFGC section 630.1: Unvented infrared radiant heaters may be used only in the following occupancies:

(1) Groups F and S.

(2) Groups U and H only with written approval.

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 6, Insert 6C, Page 1 of 1
Insert between pages 132 and 133

SPS 365.0631 Boilers. Substitute the following wording for the requirements in IFGC section 631: The provisions of ch. SPS 341 shall govern the installation, alteration and repair of boilers and pressure vessels.

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 6, Insert 6D, Page 1 of 1
Insert between pages 132 and 133

SPS 365.0632 Equipment installed in existing unlisted boilers. The requirements in IFGC section 632 are not included as part of this chapter.

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 8, Insert 8A, Page 1 of 1
Insert between pages 138 and 139

SPS 365.0800 Referenced standards. This is a department rule in addition to the requirements in IFGC chapter 8: The following standard is incorporated by reference into chs. SPS 361 to 366: ANSI Z223.1/NFPA 54–2015, National Fuel Gas Code.

Note: NFPA standards may be purchased from the National Fire Protection Association, One Batterymarch Park, P.O. Box 9101, Quincy, MA 02269–9101.

Copies of the standard adopted under this section are on file in the offices of the department and the legislative reference bureau.

Insert pages for May 1, 2018 Wisconsin Commercial Building Code, SPS 361 – SPS 366, into the International Fuel Gas Code, 2015 Edition

Wisconsin Department of Safety and Professional Services- Division of Industry Services

IFGC Chapter 9, Insert 9A, Page 1 of 1
Insert between pages 142 and 143

SPS 365.0900 Appendices. IFGC Appendices A to D are not included as part of this chapter.