



Air Admittance Valves

55. SPS 382.31(3) - 11/19/97

Are air admittance valves approved in Wisconsin? The approval of specific air admittance valves is included among the product evaluations.

151. SPS 384.10(1) - 10/4/05

May air admittance valves be installed to serve chemical waste systems? No. If chemical resistant piping is installed to serve a fixture, an air admittance valve is not permitted as a vent termination.