



Water Treatment Standards

13. 145.14 - 2/6/07

When is a water supply system considered to be existing, so that a restricted appliance could install a device or appliance? An existing water supply system exists when a fully-licensed plumber (or occupant of a single-family residence) has installed the piping from the meter or control valve of a pressure tank to the point past where the water treatment device is to be installed.

150. SPS 82.730(3) - 2/25/04

Does a laundry reuse plumbing treatment system need to comply with Table 382.70? Yes, the recycled water serving the laundry must comply with Table 382.70. This does not apply to residential suds savers, as a suds saver is not a plumbing treatment system.

152. SPS 384.10(2) - 4/1/08

How would a health care treatment device that includes a reuse system be classified for the purposes of product or plan review requirements? Devices or systems that incorporate hydrotherapy for health care and a water reuse system are classified as health care plumbing appliances. All health care plumbing appliances are required to be submitted for product approval as listed in Comm Table 84.10.